

U.S. EPA REGION II
SPCC INSPECTION CHECKLIST

FACILITY NAME _____
ADDRESS _____

INSPECTION DATE _____

:DOES NOT APPLY TO FIELD

APPENDIX "C" - SPCC INSPECTION CHECKLIST	ADEQUATELY ADDRESSED					
	PLAN			FIELD		
	YES	NO	N/A	YES	NO	N/A
40 CFR 112.3 - Requirements for Preparation and Implementation of Spill Prevention Control and Countermeasure (SPCC) Plans						
(b) Plan prepared within 6-months after facility became operational.						
Plan implemented within one year after facility became operational.						
(d) Professional Engineer's (P.E.) Certification.						
(e) Plan available during normal 8-hour day.						
(f) (1) Extension of time to prepare and implement Plan.						
(2) Required submissions for requests of time extensions.						
40 CFR 112.4 - Amendment of SPCC Plan by Regional Administrator (R.A.)						
(a) Whenever a facility discharges more than 1,000 gallons of oil into navigable waters or has two reportable spills within 12 months, the following information shall be submitted to the RA:						
(1) Name of the facility;	(1)					
(2) Name(s) of the owner or operator;	(2)					
(3) Location of the facility;	(3)					
(4) Date and year of the initial facility operation;	(4)					
(5) Maximum storage or handling capacity;	(5)					
(6) Description of the facility including maps and diagrams;	(6)					
(7) A complete copy of the SPCC Plan including amendments;	(7)					
(8) The causes of the spill, including failure analysis;	(8)					
(9) The corrective actions and/or countermeasures taken;	(9)					
(10) Additional preventive measures taken or contemplated; and	(10)					
(11) Other information as required by R.A.	(11)					
(c) All above information sent to applicable State agency.						
(d & e) R.A. requirements for SPCC Plan amendment (Explain in Report).						
(f) Appeal of amendments by facility.						
40 CFR 112.5 - Amendment of SPCC Plans by the Owners or Operators.						
(a) Amendment (and implementation within 6 months) of changes to Plan.						
(b) Three (3) year review and evaluation of SPCC Plan by management.						
(c) Amendments are certified by a Professional Engineer.						
DISCUSSION OF §112.3 TO §112.5:						
40 CFR 112.7 - Guidelines for the Preparation and Implementation of Spill Prevention Control & Countermeasure Plans						

APPENDIX "C" - SPCC INSPECTION CHECKLIST	ADEQUATELY ADDRESSED					
	PLAN			FIELD		
	YES	NO	N/A	YES	NO	N/A
(First Paragraph:)						
- Full approval of management with authority to commit resources.						
- Discussion and implementation schedule of items to be installed.						
- Plan follows sequence of §112.7						
(a) Description of spill events, including corrective actions.						
(b) Direction, rate of flow, and quantity of potential oil spills.						
(c) Secondary, containment and/or diversionary structures:						
(i) Dikes, berms or retaining walls sufficiently impervious;						
(ii) Curbing;						
(iii) Culverting, gutters or other drainage systems;						
(iv) Weirs, booms or other barriers;						
(v) Spill diversion ponds;						
(vi) Retention ponds; and/or						
(vii) Sorbent materials.						
(d) If the installation of structures or equipment as listed in §112.7(c) is not practicable as determined by the facility, the impracticability should be clearly demonstrated.						
Describe impracticability:						
The following should also be provided:						
(1) A strong oil spill contingency plan [40 CFR 109].						
(2) A written commitment of manpower, equipment and materials required to handle any quantity of oil discharged.						
Describe Contingency Plan:						
(e)(1) Facility Drainage (onshore); (excluding production facilities)						
(i) Drainage from diked storage areas have valves or other positive means to prevent an oil spill.						
(ii) Valves should be manual, open-and-closed design. Retained stormwater from diked areas should be inspected before drainage [(e)(2)(iii)(B,C & D)].						
(iii) Plant drainage from undiked areas are equipped with either: Ponds, lagoons or catchment basins to retain oil; or						
(iv) A diversion system at the discharge point that will contain a spill and return it to the facility.						
(v) Where more than one drainage water treatment unit is used, the transfer between units should be by either: Natural hydraulic (gravity) flow; or Two "lift" pumps with at least one permanently installed. Drainage will prevent oil from reaching navigable waters.						
DISCUSSION OF §112.7(a) TO §112.7(e)(1):						
40 CFR 112.7 - Guidelines for the Preparation and Implementation of Spill Prevention Control & Countermeasure Plans (Continued)						

APPENDIX "C" - SPCC INSPECTION CHECKLIST	ADEQUATELY ADDRESSED					
	PLAN			FIELD		
	YES	NO	N/A	YES	NO	N/A
(e) (2) Bulk Storage Tanks (onshore); (excluding production facilities)						
(i) Tank material/construction is compatible with fluid stored.						
(ii) Secondary containment is provided for the largest single tank plus an allowance for precipitation. Dike walls and floor are "sufficiently impervious."						
(iii) Drainage of rainwater from diked areas, by-passing treatment, is accomplished according to the following: (A) Normally the by-pass valve is sealed closed; (B) The rainwater is inspected; (C) The by-pass valve is opened/closed under supervision; and (D) Records are kept of bypassing and drainage events.						
(iv) Buried metallic storage tank: New tanks are coated and wrapped to reduce corrosion; Cathodic protection is provided for new tanks as required; Tanks are pressure tested on a scheduled basis.						
(v) Partially buried metallic tanks are avoided unless adequate coating is provided for the buried portion.						
(vi) Aboveground tanks are tested by one of the following methods: Hydrostatic testing; Visual inspection; and/or Shell thickness testing (comparison records maintained). All bulk storage tanks are inspected periodically.						
(vii) Internal heating coil leakage is controlled by the following: (A) Monitoring the stream return or exhaust lines for oil; Passing the steam lines through a separation system; or (B) Installing external heating system.						
(viii) Tanks are fail-safe engineered by one of the following: (A) High liquid level alarms with an audible or visual signal; (B) High liquid level pump cutoff devices; (C) Direct signal between the tank gauger and pumping station; (D) A fast response system to detect oil level such as digital computers, telepulse, direct visual gauges, or equal. (E) Sensing devices should be inspected/tested periodically.						
(ix) Plant effluent observed frequently to detect upsets.						
(x) Oil leaks from tanks should be promptly corrected.						
(xi) Mobile or portable oil storage tanks should be properly located to prevent oil from reaching navigable waters. Secondary containment should be provided.						
40 CFR 112.7 - Guidelines for the Preparation and Implementation of Spill Prevention Control & Countermeasure Plans (Continued)						

[illegible]

APPENDIX "C" - SPCC INSPECTION CHECKLIST	ADEQUATELY ADDRESSED					
	PLAN			FIELD		
	YES	NO	N/A	YES	NO	N/A
40 CFR 112.7 - Guidelines for the Preparation and Implementation of Spill Prevention Control & Countermeasure Plans (Continued)						
(e)(5) Oil production facilities (onshore).						
(ii) (A) Secondary containment drains are closed and locked.						
The water should be inspected before drainage.						
Accumulated oil should be disposed of by approved methods.						
(B) Ditches, sumps, traps, etc. should be kept clean of oil.						
(iii)(A) Tank material/construction is compatible with fluid.						
(B) Tanks and treatment facilities have secondary containment.						
(C) Tanks should be visually inspected and defects corrected.						
(D) Tank batteries should be fail-safe engineered as follows:						
(1) Adequate tank capacity;						
(2) Overflow equalizing lines between tanks;						
(3) Adequate vacuum protection to prevent tank collapse; or						
(4) High liquid level alarms.						
(iv) All aboveground equipment should be periodically inspected, corrosion protected, and repaired as necessary.						
Preventive maintenance programs should be utilized.						
(e)(6) Oil drilling and facilities (onshore).						
(i) Equipment should be located to prevent spilled oil from reaching navigable waters.						
(ii) Catchment basins or diversion structures should be provided to intercept and contain oil spills.						
(iii) A blowout prevention (BOP) assembly and well control system should be installed as necessary to prevent release of oil.						
(e)(7) Oil drilling, production or facilities (offshore).						
DISCUSSION OF §112.7(e)(5) to §112.7(e)(6):						
40 CFR 112.7 - Guidelines for the Preparation and Implementation of Spill Prevention Control & Countermeasure Plans (Continued)						

[illegible]